

CUS150M1

TEST DATA

IEC61000 SERIES

INDEX

| | PAGE |
|--|------|
| 1. Electrostatic Discharge Immunity Test (IEC61000-4-2) | R-1 |
| 2. Radiated Radio-Frequency Electromagnetic Field Immunity Test (IEC61000-4-3) | R-2 |
| 3. Electrical Fast Transient / Burst Immunity Test (IEC61000-4-4) | R-3 |
| 4. Surge Immunity Test (IEC61000-4-5) | R-4 |
| 5. Conducted Disturbances Induced by Radio-Frequency Field Immunity Test (IEC61000-4-6) | R-5 |
| 6. Power Frequency Magnetic Field Immunity Test (IEC61000-4-8) | R-6 |
| 7. Voltage Dips, Short Interruptions Immunity Test (IEC61000-4-11) | R-7 |

Terminology used

FG Frame GND

※ Test results are reference data based on our standard measurement condition.

MODEL : CUS150M1

(1) Equipment Used


Electro Static Discharge Simulator : NSG435 (SCHFFNER)
 Discharge Resistance : 330Ω Capacity : 150pF

(2) Test Conditions

• Input Voltage : 115, 230VAC • Output Voltage : Rated
 • Output Current : 100% • Polarity : +, -
 • Test Times : 10 times • Discharge Interval : > 1 second
 • Ambient Temperature : 25°C

(3) Test Method and Device Test Point

Contact Discharge : ⚡, Mounting screw
 Air Discharge : ⚡, Input and output terminal, Mounting screw



(4) Acceptable Conditions

1. Output voltage regulation not to exceed ±5% of initial (before test) value during test.
2. Output voltage to be within regulation specification after the test.
3. Along with 1 and 2, without the occurrence of smoke and fire, as well as no output failure.

(5) Test Result

| Contact Discharge (kV) | CUS150M1-12/18/24/36/48 | Air Discharge(kV) | CUS150M1-12/18/24/36/48 |
|------------------------|-------------------------|-------------------|-------------------------|
| 2 | PASS | 2 | PASS |
| 4 | PASS | 4 | PASS |
| | | 8 | PASS |

2. Radiated Radio-Frequency Electromagnetic Field Immunity Test (IEC61000-4-3)

MODEL : CUS150M1


(1) Equipment Used

- SML 03(RS CORPORATION)
- HL 046(RS CORPORATION)
- AR500W 1000A(AR CORPORATION)
- FM5004(AR CORPORATION)
- FP6001(AR CORPORATION)

(2) Test Conditions

- Input Voltage : 115, 230VAC
- Output Voltage : Rated
- Output Current : 100%
- Amplitude Modulated : 80%, 1kHz
- Electromagnetic Frequency : 80~1000MHz
- Ambient Temperature : 25°C
- Wave Angle : Horizontal and Vertical
- Distance : 3.0m
- Sweep Condition : 1.0%Step Up, 2.8 Seconds Hold
- Test Angle : Top/Bottom, Both Sides, Front/Back

(3) Test Method



(4) Acceptable Conditions

1. Output voltage regulation not to exceed $\pm 5\%$ of initial (before test) value during test.
2. Output voltage to be within regulation specification after the test.
3. Along with 1 and 2, without the occurrence of smoke and fire, as well as no output failure.

(5) Test Result

| Radiation Field Strength (V/m) | CUS150M1-12/18/24/36/48 |
|--------------------------------|-------------------------|
| 1 | PASS |
| 3 | PASS |
| 10 | PASS |

3. Electrical Fast Transient / Burst Immunity Test (IEC61000-4-4)

MODEL : CUS150M1

(1) Equipment Used


EFT/B Generator : FNS-100L (NOISEKEN)

(2) Test Conditions

- Input Voltage : 115, 230VAC
- Output Voltage : Rated
- Output Current : 100%
- Test Time : 1 minute
- Polarity : +, -
- Ambient Temperature : 25°C
- Number of Tests : 3 times

(3) Test Method and Device Test Point

Apply to (N, L, \neq), (N, L), (N), (L), (\neq).



(4) Acceptable Conditions

1. Output voltage regulation not to exceed $\pm 5\%$ of initial (before test) value during test.
2. Output voltage to be within output voltage regulation specification after the test.
3. Along with 1 and 2, without the occurrence of smoke and fire, as well as no output failure.

(5) Test Result

| Test Voltage (kV) | Repetition Rate (kHz) | CUS150M1-12/18/24/36/48 |
|-------------------|-----------------------|-------------------------|
| 0.5 | 5 / 100 | PASS |
| 1 | 5 / 100 | PASS |
| 2 | 5 / 100 | PASS |

4. Surge Immunity Test (IEC61000-4-5)

MODEL : CUS150M1

(1) Equipment Used

Surge Generator : 6100 (SCHAFFNER)

Coupling Impedance : Common 12Ω Coupling Capacitance : Common 9μF


Normal 2Ω Normal 18μF

(2) Test Conditions

- Input Voltage : 115, 230VAC
- Output Voltage : Rated
- Output Current : 0, 100%
- Number of Tests : 3 times
- Polarity : +, -
- Mode : Common, Normal
- Phase : 0, 90 deg
- Ambient Temperature : 25°C

(3) Test Method and Device Test Points

Apply to Common mode (N-≡, L-≡) and Normal mode (N-L).



(4) Acceptable Conditions

1. Output voltage regulation not to exceed ±5% of initial (before test) value during test.
2. Output voltage to be within regulation specification after the test.
3. Along with 1 and 2, without the occurrence of smoke and fire, as well as no output failure.

(5) Test Result

| Common | | Normal | |
|-------------------|-------------------------|-------------------|-------------------------|
| Test Voltage (kV) | CUS150M1-12/18/24/36/48 | Test Voltage (kV) | CUS150M1-12/18/24/36/48 |
| 0.5 | PASS | 0.5 | PASS |
| 1 | PASS | 1 | PASS |
| 2 | PASS | 2 | PASS |
| 4 | PASS | | |

5. Conducted Disturbances Induced by Radio-Frequency Field Immunity Test (IEC61000-4-6)

MODEL : CUS150M1

(1) Equipment Used


RF POWER AMPLIFIER : (AR U.S.A)

SIGNAL GENERATOR : IFR 2023A (IFR U.K)

(2) Test Conditions

- Input Voltage : 115, 230VAC
- Output Voltage : Rated
- Output Current : 100%
- Electromagnetic Frequency : 150kHz~80MHz
- Ambient Temperature : 25°C
- Sweep Condition : 1.0%Step Up, 2.8 Seconds Hold

(3) Test Method



(4) Acceptable Conditions

1. Output voltage regulation not to exceed $\pm 5\%$ of initial (before test) value during test.
2. Output voltage to be within regulation specification after the test.
3. Along with 1 and 2, without the occurrence of smoke and fire, as well as no output failure.

(5) Test Result

| Voltage Level (V) | CUS150M1-12/18/24/36/48 |
|-------------------|-------------------------|
| 1 | PASS |
| 3 | PASS |
| 10 | PASS |

6. Power Frequency Magnetic Field Immunity Test (IEC61000-4-8)

MODEL : CUS150M1

(1) Equipment Used

AC Power Source : 1501L (California Instrument)

Helmholts Coil : HHS5215 (Spulen)

(2) Test Conditions


•Input Voltage : 115, 230VAC •Output Voltage : Rated

•Output Current : 100% •Magnetic Frequency : 50Hz

•Ambient Temperature : 25°C •Direction : X, Y, Z

•Test Time : More than 10 seconds(Each direction)

(3) Test Method and Device Test Point



(4) Acceptable Conditions

1. Output voltage regulation not to exceed $\pm 5\%$ of initial (before test) value during test.
2. Output voltage to be within regulation specification after the test.
3. Along with 1 and 2, without the occurrence of smoke and fire, as well as no output failure.

(5) Test Result

| Magnetic Field Strength (A/m) | CUS150M1-12/18/24/36/48 |
|-------------------------------|-------------------------|
| 1 | PASS |
| 3 | PASS |
| 10 | PASS |
| 30 | PASS |

7. Voltage Dips, Short Interruptions Immunity Test (IEC61000-4-11)

MODEL : CUS150M1


(1) Equipment Used

Test Generator : PCR2000L (KIKUSUI)

(2) Test Conditions

| | | | |
|-------------------|---------------|-----------------------|------------------------|
| • Input Voltage | : 115, 230VAC | • Output Voltage | : Rated |
| • Output Current | : 100% | • Ambient Temperature | : 25°C |
| • Number of Tests | : 3 times | • Test interval | : More than 10 seconds |

(3) Test Method and Device Test Point



(4) Acceptable Conditions

1. Output voltage to be within output voltage regulation specification after the test.
2. Smoke and fire do not occur.

(5) Test Result

| Test Level | Dip rate | Continue Time | CUS150M1-12/18/24/36/48 |
|------------|----------|---------------|-------------------------|
| 70% | 30% | 500ms | PASS |
| 40% | 60% | 200ms | PASS |
| 0% | 100% | 20ms | PASS |
| 0% | 100% | 5000ms | PASS |