

CUS2000M

Instruction Manual

BEFORE USING THE POWER SUPPLY UNIT

Be sure to read this instruction manual thoroughly before using this product. Pay attention to all cautions and warnings before using this product. Incorrect usage could lead to an electrical shock, damage to the unit or a fire hazard.

DANGER

Never use this product in locations where flammable gas or ignitable substances are present.

INSTALLATION WARNING

- When installing, ensure that work is done in accordance with the instruction manual. When installation is improper, there is risk of electric shock and fire.
- Installation shall be done by Service personnel with necessary and appropriate technical training and experience. There is a risk of electric shock and fire.
- Do not cover the product with cloth or paper etc. Do not place anything flammable around. This might cause damage, electric shock or fire.

WARNING ON USE

- Do not touch this product or its internal components while circuit in operation, or shortly after shutdown. You may receive a burn.
- While this product is operating, keep your hands and face away from it as you may be injured by an unexpected situation.
- For products with no cover, do not touch them as there are high-voltage and high temperature parts inside. Touching them might cause injury such as electric shock or burn.
- There are cases where high voltage charge remains inside the product. Therefore, do not touch even if they are not in operation as you might get injured due to high voltage and high temperature. You might also get electric shock or burn.
- Do not make unauthorized changes to this product nor remove the cover as you might get an electric shock or might damage the product. We will not be held responsible after the product has been modified, changed or disassembled.
- Do not use this product under unusual condition such as emission of smoke or abnormal smell and sound etc. Please stop using it immediately and shut off the product. It might lead to fire and electric shock. In such cases, please contact us. Do not attempt repair by yourself, as it is dangerous for the user.
- Do not operate and store these products in environments where condensation occurs due to moisture and humidity. It might lead fire and electric shock.
- Do not drop or apply shock to this product. It might cause failure. Do not operate these products, when mechanical stress is applied.

CAUTION ON MOUNTING

- Confirm connections to input/output terminals are correct as indicated in the instruction manual before switching on.
- Input /Output line, please use the wires as short and thick as possible.
- Do not use this product in special environment with strong electromagnetic field, corrosive gas or conductive substances and direct sunlight, or places where product is exposed to water or rain.
- Mount this product properly in accordance with the instruction manual, mounting direction and shall be properly be ventilated.
- Please shut down the input when connecting input and output of the product.
- When installing in environment where conductive foreign, dust and liquid may be present, please consider penetration of above foreign material in the power supply by installing filter, to prevent trouble or malfunction.

CAUTION ON USE

- Product individual notes are shown in the instruction manual. If there is any difference with common notes individual notes shall have priority.
- Before using this product, be sure to read the catalog and instruction manual. There is risk of electric shock or damage to the product or fire due to improper use.
- Input voltage, Output current, Output power, ambient temperature and ambient humidity should be kept within specifications, otherwise the product will be damaged, or cause electric shock or fire.
- If the built-in fuse is blown, do not use the product even after replacing the fuse, as there is risk of abnormality inside. Be sure to request repair to our company.
- Double pole, neutral fusing. Disconnect mains before servicing.
(Double pôle/fusible sur le neutre. Débrancher l'alimentation avant l'entretien.)
- For products without built-in protection circuit (element, fuse, etc.), insert fuse at the input to prevent smoke, fire during abnormal operation. As for products with built-in protection circuit, depending on usage conditions, built-in protection circuit might not work. It is recommended to provide separate proper protection circuit.
- For externally mounted fuse do not use other fuses aside from our specified and recommended fuse.
- This product was made for general purpose electronic equipment use and is not designed for applications requiring high safety (such as extremely high reliability and safety requirements. Even though high reliability and safety are not required, this product should not be used directly for applications that have serious risk for life and physical safety. Take sufficient consideration in fail-safe design (such as providing protective circuit or protective device inside the system, providing redundant circuit to ensure no instability when single device failure occurs).
- When used in environments with strong electromagnetic field, there is possibility of product damage due to malfunction.
- When used in environment with corrosive gas (hydrogen sulfide, sulfur dioxide, etc.), there is possibility that they might penetrate the product and lead to failure.
- When used in environments where there is conductive foreign matter or dust, there is possibility of product failure or malfunction.
- Provide countermeasure for prevention of lightning surge voltage as there is risk of damage due to abnormal voltage.
- Connect together the frame ground terminal of the product and the ground terminal of the equipment for safety and noise reduction. If this ground is not connected, there is risk of electric shock.
- Parts with lifetime specifications (built-in fan electrolytic capacitor) are required to be replaced periodically. Set the overhaul period depending on the environment of usage and perform maintenance. Also, note that there are cases when EOL products cannot be overhauled.
- Take care not to apply external abnormal voltage to the output. Especially, applying reverse voltage or overvoltage more than the rated voltage to the output might cause failure, electric shock or fire.
- Take care not to perform frequent power ON/OFF operations, otherwise causing failure for power supply.
- Take care not to apply mechanical stress on surface mounted components otherwise causing failure for power supply.
- This product has possibility that hazardous voltage might occur in output terminal depending on failure mode. The output of these products must be protected in the end use equipment to maintain SELV.
- For product with built-in fan, do not block the air intake and exhaust as this might lead to fire.
- The output power of this product is considered to be hazardous energy level. (The voltage is more than or equal to 2V and the power is more than equal to 240VA) It must not be made accessible to users. Protection must be provided for service engineers against indirect contact with the output terminal and to prevent any tools drop across the outputs. While working on this product, the AC input must be switched off and the input and output voltage should be zero.

General installation instructions

- These products are Class I and must therefore be reliably earthed and professionally installed in accordance with the prevailing electrical wiring regulations and the safety standards covered herein.
- These products are IPX0, and therefore chemicals/solvents, cleaning agents and other liquids must not be used.
- The first protective earth connection in the final installation must be marked with the protective earth symbol.

Special Instructions for IEC/EN/ES/CSA 60601-1

- These products are designed for continuous operation within an overall enclosure, and must be mounted such that access to the mains terminals is restricted. See Clause 16, IEC/60601-1 2nd edition or clause 8 IEC/EN/ES/CSA 60601-1 3rd edition.
- These products are NOT suitable for use in the presence of flammable anesthetics mixtures with air or with oxygen or with nitrous oxide.
- These products are classed as ordinary equipment according to IEC/EN/ES/CSA60601-1 and are NOT protected against the ingress of water.
- Reference should be made to local regulations concerning the disposal of these products at out of their useful life.
- These products have not been assessed to IEC/EN60601-1-2 (EMC) but EMC test data is available from TDK-Lambda Corporation.
- For IEC 60601-1 2nd Edition, these products have a reinforced insulation barrier between input and output. For IEC/EN/ES/CSA 60601-1 3rd edition, these products provide reinforced insulation between input and outputs of 2 MOPP, 1 MOPP from input to earth and 1 MOPP from output to earth.
- These products have SELV outputs.
- All outputs have basic spacing's to earth rated for mains – 250Vac, and due consideration must be given to this in the end product design.

Important safety instructions

- **Servicing**

These products are not customer serviceable. Repairs may only be carried out by TDK-Lambda Corporation or their authorized agents. These products are not authorized for use as critical components in nuclear control systems, life support systems or equipment for use in hazardous environments without the express written approval of the Managing Director of TDK-Lambda Corporation.

- **Safety Class of Protection**

These products are designed for the following parameters: Material Group IIIB, Pollution Degree 2, Over voltage Category II, class I (earthed)

Indoor use as part of an overall equipment such that the product is accessible to service engineers only.

EMC performance

- Immunity (IEC61000-6-2)

Test	Standard
Electrostatic discharge	IEC61000-4-2
Electromagnetic field	IEC61000-4-3
Fast / burst transient	IEC61000-4-4
Surge immunity	IEC61000-4-5
Conducted RF immunity	IEC61000-4-6
Power frequency magnetic field	IEC61000-4-8
Voltage dips, variations, interruptions	IEC61000-4-11
Radiated Field in Close Proximity	IEC61000-4-39

- Emissions

Test	Standard	Comments
Radiated electric field	EN55032	Class B (as per CISPR 32)
Conducted emissions	EN55032	Class B (as per CISPR 32)
Conducted harmonics	IEC61000-3-2	Compliant

NOTE

- Take note that traces of sheet metal processing be left in our power supplies.
- When disposing product, follow disposal laws of each municipality.
- Published EMI (CE, RE) or immunity is the result when measured in our standard measurement conditions and might not satisfy specification when mounted and wired inside end-user equipment. Use the product after sufficiently evaluating at actual end-user equipment.
- When exporting our products, apply for necessary permissions as required by rules and regulations of Foreign Exchange and Foreign Trade Control Act.
- Catalogue, contents of the instruction manual may be changed without a prior notice. Refer to latest catalogue or instruction manual.
- Reproduction or reprinting the instruction manual or its portion is forbidden without our permission.

LONG-TERM STORAGE METHOD AND LONG-TERM STORAGE PERIOD

- Please keep the product in carton box.
- Please do not apply excessive vibration, shock or mechanical stress applied directly to the product.
- Please keep away from direct sunlight.
- For long-term storage temperature and humidity, the following conditions shall be used as a guideline:

Temperature range : 5°C ~ 30°C

Humidity range : 40% ~ 60%RH

Please keep away from the places where temperature and humidity can change drastically. It can cause condensation on the product or deterioration.

- For long-term storage period, we recommend to use within 2 years after receiving the product.

< Soldering and PCB mounted products: On Board, Power Module and etc. >

For products that have been received for more than 1 year, please check lead oxidation and solderability.

In addition, SMD type products may have MSL (Moisture Sensitivity Level) provision.

Please be sure to read the instruction manual and delivery specifications.

< Unit type or PCB type of products: the product is used an aluminum electrolytic capacitor >

There is tendency that the leakage current of an aluminum electrolytic capacitor may increase when stored without using for a long time. This phenomenon can be improved by applying voltage to the aluminum electrolytic capacitor to reduce the increased leakage current through the self-recovery effect of the electrolyte. For reference, before using products that have been stored for a very long time, please warm-up first for 30 minutes or more without taking load.

< Criterion of warm up voltage condition >

(1) Implementation period: 1 year or above after the delivery.

(2) Electrical continuity condition.


Input voltage: Rating.

Load: 0A.

Ambient temperature: Normal temperature.

Time: 30 minutes or more.

1. Model name identification method



Option (*1)
Rated Output Voltage
Output Power (actual output power refers to the specification)
Series Name.


Note (*1) Blank : Standard type.
/ SF : Single fuse model.

2. Terminal Explanation


CUS2000M

- ① L: Input terminal Live line (Fuse in line) (M3.5 screw).
- ② N: Input terminal Neutral line (Fuse in line) (M3.5 screw).
- ③ $\perp$: Earth terminal (M3.5 screw).
- ④ V+: + Output Terminal (M4 screw).
- ⑤ V-: - Output Terminal (M4 screw).
- ⑥ VR51: Output voltage adjustment trimmer.
The output voltage rises when the trimmer is turned clockwise.
- ⑦ CN52 Terminal.


Input side



Top side



Configuration and Function of CN52 is shown as below.

CN52	Pin No.	Configuration	Function
	1	STBY+	Standby supply + (5V+). Please refer to 6-12.
	2	STBY-	Standby supply - (5V-). This pin is connected to V- internally. Please refer to 6-12.
	3	S+	Remote sense +.
	4	S-	Remote sense -.
	5	NC	No connection.
	6	PG	Power good signal. Please refer to 6-13.
	7	R+	Remote ON/OFF terminal +. Please refer to 6-14.
	8	R-	Remote ON/OFF terminal -. Please refer to 6-14.

*TB1, TB51, TB52, CN52 Connector & Housing & Terminal Pin

	Connectors used	Matching housings	Matching pins	Maker
Input (TB1)	T950C-01-A495-03P(KN) (M3.5 terminals)	—	—	TIELEE
Output (TB51, TB52)	M4 terminals	—	—	—
Output (CN52)	B8B-PHDSS(LF)(SN)	PHDR-08VS	SPHD-001T-P0.5	JST

Hand Crimping Tool: YC-610R(JST), YC-611R(JST).


Use maker recommended crimping tool.

Matching housings and pins are not included in product.

Recommended torque for M3.5 screws of TB1: 0.8~1.2N·m(8.2~12.2kgf·cm).

Recommended torque for M4 screws of TB51&TB52: 1.18N·m(12kgf·cm) MAX.

3. Block Diagram




● Fuse rating : 25A


● Circuit topology, switch frequency
PFHC circuit: active filter 65kHz (Typ).
Output circuit: LLC resonant 50k~300kHz.
Standby supply circuit: Flyback 115kHz (Typ).

4. Sequence time chart

Input voltage ON/OFF sequence time chart




Remote ON/OFF sequence time chart




Note: (*2) This sequence is using external voltage.


OVP recovery sequence time chart (1)




OVP recovery sequence time chart (2)




Main output OCP (latch) recovery sequence time chart (1)




Main output OCP (latch) recovery sequence time chart (2)



Main output OCP (not latched) recovery sequence time chart



Standby supply OCP recovery sequence time chart




Note: (*2) This sequence is using external voltage.

5. Connection Method

Pay attention to the input wiring. If it is connected to wrong terminal, the power supply may be damaged.

- Input must be off when making connections.
- Mounting hole and $\perp$ terminal of input connector must be connected to protective earth of the equipment.
- The output load line and input line shall be separated to improve noise sensitivity.
- Do not apply stress to PCB, when connecting or removing connectors.
- Do not apply stress to the components when connecting or removing connectors.
- Remote ON/OFF control lines shall be twisted or used shielded wires. Separate from load line.
- Remote sensing lines shall be twisted or used shielded wires.

End equipment connection




6. Explanation of Function and Precautions

6-1. Input Voltage Range

Input voltage range is single phase 85-265VAC (47-63Hz). Input voltage, which is out of specification, might lead unit damage. For cases where conformance to various safeties required, described as 100-240VAC (50-60Hz). If input voltage is less than 170VAC, output power needs to be derated.

Derating curve of the input voltage

MODEL: CUS2000M-12 - - - - -
MODEL: CUS2000M-24/36/48 _____



Input voltage (VAC)	MOUNTING A, B, C, D, E	
	LOAD (W)	
	CUS2000M-12	CUS2000M-24/36/48
85	1350	1440
90~170	1500	1600
170~265	1600	2000

6-2. Output Voltage Range

Output voltage is set the rated value at shipment.

V.ADJ trimmer (VR51) can adjust the output voltage within the specification range. To turn the trimmer clockwise, the output voltage will be increased. Take note when the output voltage is increased excessively, over voltage protection (OVP) function may be triggered and output voltage will be shut down. Furthermore, when increasing the output voltage reduce the output current so as not to exceed the maximum output power.

6-3. Inrush Current

These products equipped power thermistor to limit the inrush current. Higher current will flow at higher ambient temperature or re-input condition. Please select input switch and fuse carefully with the high temperature and re-input the power condition. The inrush current value is under cold start at 25°C in the specification.

6-4. Over Voltage Protection (OVP)

The OVP function (Inverter shut down method, manual reset type) is provided. Please refer to its specification for OVP range. When OVP triggers, the output will be shut down. In addition, the setting value of OVP is fixed and not adjustable. Pay attention not to apply higher voltage externally to the output terminal to avoid unit failure. In case of inductive load, put protective diode in series to the output power line.

Two methods to recovery from OVP:

- Turn off the input of power supply for a few minutes, and then re-input.
- Remote OFF, and then remote ON again. (Refer to 6-14.)

6-5. Over Temperature Protection (OTP)

Over temperature shut down function is provided.

When ambient or internal temperature rises abnormally, over temperature protection function operates and output will be shut down. After shutting down, remove the input and cool it down to reset over temperature protection, and then re-input.

Over temperature protection function operates at out of the specification area.


This function may not activate or cannot avoid power supply damage depending on the situation.

6-6. Over Current Protection (OCP)

These products provide the Hiccup mode with automatic recovery. OCP function operates when the output current exceeds 105% of maximum DC output current at forced air cooling of specification. The outputs will be automatically recovered when the overload condition is canceled, however the outputs may be latched off when shorted condition happens. Never operate the unit under over current or shorted conditions, which may lead damage or insulation failure. OCP setting is fixed and not to be adjusted externally.


6-7. Output Ripple & Noise

The standard specification for maximum ripple value is measured according to measurement circuit specified as below. When load lines are longer, ripple will become larger. In this case, electrolytic capacitor, film capacitor, etc. might be necessary to use across the load terminal. The output ripple cannot be measured accurately if the probe ground lead of oscilloscope is too long.



6-8. Series Operation


For series operation, either method (A) or (B) is possible.



Note: In case of (A), please select a bypass diode (*3) with maximum forward current rating more than output load current. And maximum reverse voltage must withstand each power supply output voltage.
 Never use when one of the units do not operate, which may lead damage.


6-9. Parallel Operation

(A) To increase the Output Current is not possible.



(B) Operation as a Backup System is possible.


1. Increase the output voltage to compensate for the diode forward voltage drop (VF).
2. Adjust the output voltage of each power supply to the same value.
3. Output voltage and output power shall be kept within the specified range.
4. Use blocking diode to prevent reverse current. Diode current rating must be more than output load current.



6-10. Isolation Test

Isolation resistance between Output and $\perp$ is more than 100M Ω at 500VDC. For safety operation, voltage setting of DC isolation tester must be done before the test. Ensure that the unit is fully discharged after the test.



- Output - $\perp$ terminal : 500VDC More than 100M Ω



6-11. Withstand Voltage Test



These products are designed to withstand 4.0kVAC between input and output, 2.0kVAC between input and $\perp$ and 1.5kVAC between output and $\perp$ for 1 minute. When testing withstand voltage, set current limit of the withstand voltage test equipment to 20mA. The applied voltage must be gradually increased from zero to the testing value and then gradually decreased for shut down. When timer is used, the power supply may be damaged by high impulse voltage at timer switch on and off. Connect input and output as follows.

- Input – Output (Dashed line): 4kVAC, 1 minute (20mA)
- Input – $\perp$ (Solid line) : 2kVAC, 1 minute (20mA)
- Output – $\perp$: 1.5kVAC, 1 minute (20mA)



Note: In case of using external noise filter, capacitance between “Input and $\perp$ ” might be increased. When testing withstand voltage between “Input and Output”, there is a possibility exceeding withstand voltage between “Output and $\perp$ ” (1.5kVAC). Please check the voltage between “Output and $\perp$ ”. If the voltage exceeding withstand voltage, please add external capacitor to “Output and $\perp$ ”. It can decrease the voltage.

On the other hand, no need to check the voltage in case of “Output and $\perp$ ” is shorted.



6-12. Standby supply

A fixed 5V Standby supply is provided through STBY+ and STBY- of CN52. And output derating should be considered according to the input voltage and remote on/off.

6-13. Power Good Signal

Power Good is provided warning signal before loss of output voltage since AC fail through PG and STBY-.

Power Good signal shows “High” level (4.5V~5V) to indicate power supply operating normal, and can source maximum 2mA current.

When power supply stops operating, the signal will turn to “Low” level (0V~0.5V), and the maximum sink current is 1mA.


6-14. Remote ON/OFF Control

Using this function allows the user to turn the output on and off without having to turn the AC input off and on.

It is controlled by the voltage applied to R+ and R-. This circuit is in the Secondary side of the power supply unit.

Do not connect in the primary side of power supply unit.

And this circuit is isolated from the output of power supply unit.



The control mode is shown below


+R & -R terminal condition	Output condition
SW OFF (Lower than 0.5V)	ON
SW ON (Higher than 3.0V)	OFF

External voltage : E	External resistance : R
3 ~ 7VDC	No required
7 ~ 20VDC	2kΩ
20 ~ 30VDC	10kΩ


Remote ON/OFF control circuit can be configured by supply from STBY+ terminal.

Example of connecting remote ON/OFF control application:

Sample A




Sample B



6-15. Remote Sensing (S+, S- terminal)


This function compensates the voltage drop of wiring from output terminals to load terminals. Connect “S+” terminal to “+” terminal of load and “S-” terminal to “-” terminal of load with sensing wires. The total line voltage drop (+ sideline and - sideline) shall be less than 0.5V. In case that sensing lines are too long, it is necessary to put an electrolytic capacitor at the load terminals.



7. Mounting Method

7-1. Mounting Directions

The standard mounting is (A). Mounting (B), (C), (D), (E) and side mounting are also possible.



7-2. Output Derating vs. Ambient temperature

Make sure that the specified temperature range is maintained. Refer to the output derating below. Load (%) of derating curve indicates output power.


Note: Output derating versus input voltage should be considered.

Please refer to the output derating versus input voltage curve 6-1 for detail.

If output voltage is raised higher than nominal, maximum power derating versus high output voltage should be considered.

Main Output Derating versus Operating Ambient Temperature (Ta)


MODEL: CUS2000M-12/24/36/48:



Ta (°C)	LOAD (%)
-20 - +40	100
50	86.7
60	73.3
70	60

Main Output Power Derating versus High Output Voltage

MODEL: CUS2000M-12/24/36/48:




Output voltage	Maximum Output Power (%)
Nominal output voltage	100
Maximum output voltage	95

Note: The maximum voltage of each models.

Model	Maximum Output Voltage
CUS2000M-12	12.6V
CUS2000M-24	25.2V
CUS2000M-36	37.8V
CUS2000M-48	50.4V

Standby Supply Output Derating versus Operating Ambient Temperature (Ta)

MODEL: CUS2000M-12/24/36/48:



Ta (°C)	LOAD (%)	
	Main output ON	Main output OFF
-20	80	80
-10 ~ 40	100	100
50	100	73.3
60	100	46.7
70	80	20

Peak Output Power

Peak output power is available.

For peak output power using, the RMS power should not be higher than the Maximum Output Power (load derating versus Input voltage, Operating temperature and high output voltage should be considered), and the maximum duty of peak power (40%) and maximum peak load time (4 seconds) should be limited too.

Below is typical application:

1. RMS power is calculated using the following formula:

$$\text{RMS power} = ((\text{peakpower}^2 \times T1 + \text{reducedpower}^2 \times T2) / (T1 + T2))^{1/2}$$


Where T1 = peak power time on in seconds.
T2 = reduced power time on in seconds.

2. Peak output power up to 4 seconds is allowed.

$$T1 \leq 4 \text{ s.}$$

3. Maximum duty of peak power should be less than 40%.

$$T1/(T1+T2) \leq 40\%$$



7-3. Mounting Method

- (1) These models are forced air cooling type power supply.

The power supply has ventilating holes on the front and back side panels. Keep these two areas freely as much as possible. The power supply may cause damage when its intake conductive material, dust and liquid. Never use in the dusty environment.


- (2) The maximum allowable penetration depth for the bottom mounting screws with 4-M3 screws is 4.5 millimeters, and for the side mounting screws with 8-M3, it is 3.2 millimeters.

Incomplete thread of mounting screw should not be penetrated.

- (3) Rear mounting from bottom side with 4-M3 screws is recommended to comply the vibration and shock specification.

Recommended torque for mounting screw: M3 screws: $0.49\text{N}\cdot\text{m}$ ($5.0\text{kgf}\cdot\text{cm}$).

- (4) Recommend to connect mounting hole to protective ground of system.



8. Wiring Method

- (1) The output load line and input line shall be separated each other and twisted individually to improve noise.
- (2) Use all lines as thick and short as possible to made lower impedance.
- (3) Noise can be reduced by attaching a capacitor to the load terminals.
- (4) For safety and EMI considerations, connect mounting hole and $\perp$ with the terminal of protective earth of equipment firmly.

9. The life expectancy

The life of the power supply depends on the life of the built-in aluminum electrolytic capacitor being used and fan mounted products will depend on fan life. Each life is described in reliability data.

The life of the aluminum electrolytic capacitor varies depending on the load current of the power supply, and the ambient temperature. Please refer to "Electrolytic Capacitor Lifetime".

The life of the fan depends on the fan exhaust temperature. Please refer to "Fan Life Expectancy".

Please do not use the product which passed over the life expectancy. There is a risk of unexpected output shut down and specifications may not be satisfied.

Please contact us for maintenance or exchange the product which passed over the life expectancy.

10. External Fuse Rating

Refer to the following fuse rating when selecting the external fuses that are to be used on input line. Surge current flows when line turns on. Have to use fast-blow and high breaking capacity fuse. Fuse rating is considered by in-rush current value at line turn-on. Do not select the fuse according to input current (RMS.) values under the actual load condition.

CUS2000M series: F25AH

11. Before concluding that the unit is at fault

- (1) Check if the rated input voltage is connected.
- (2) Check if the wiring of input and output is correct.
- (3) Check if the wire thickness is enough.
- (4) Check if the output current and output wattage dose not over specification.
- (5) Audible noise can be heard when input voltage waveform is not sinusoidal wave.
- (6) Audible noise can be heard during Dynamic-Load operation.
- (7) Ensure that a large capacitor is not connected across the output terminals. Please use within maximum capacitance shown below.

Model	CUS2000M-12	CUS2000M-24	CUS2000M-36	CUS2000M-48
Maximum external capacitance	12000uF	10000uF	10000uF	10000uF

12. Warranty Period

The warranty period applies for below conditions.

$T_a \leq 40^\circ\text{C}$

Output current $\leq 90\%$

For damages occurring at normal operation within this warranty period, repair is free of charge.

For other mounting directions inquire to TDK-Lambda.

Following cases are not covered by warranty

- (1) Improper usage like dropping products, applying shock and defects from operation exceeding specification of the unit.
- (2) Defects resulting from natural disaster (fire, flood etc.)
- (3) Unauthorized modifications or repair.
- (4) Condition of continuously dynamic load or AC power on/off.

13. Altitude

CUS2000M is safety approved for operation at below altitude.

- Up to 5000m by IEC62368-1 clearance requirement.

- Up to 5000m by IEC60601-1 clearance requirement.

Thermal evaluation should be considered for products operating at elevated altitudes above 2000m.

14. CE MARKING/ UKCA MARKING

CE MARKING

CE Marking, when applied to a product or packing material for a product covered by this handbook, indicates compliance with the Low Voltage Directive, EMC Directive and RoHS Directive.

UKCA MARKING

UKCA Marking, when applied to a product or packing material for a product covered by this handbook, indicates compliance with the Electrical Equipment (Safety) Regulations, Electromagnetic Compatibility Regulations and Restriction of the Use of Certain Hazardous Substances in Electrical & Electronic Equipment Regulations.