



Ref. Certif. No.

DE 2-031055

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product	Switch Mode Power Supply
Name and address of the applicant	TDK-Lambda Americas Inc. 401 Mile of Cars Way, Suite 325 National City CA 91950, USA
Name and address of the manufacturer	TDK-Lambda Americas Inc. 401 Mile of Cars Way, Suite 325 National City CA 91950, USA
Name and address of the factory	TDK-Lambda Malaysia Sdn. Bhd. PLO 33, Kawasan Perindustrian Senai 81400 Senai, Johor, Malaysia
Ratings and principal characteristics	AC 100-240V, 50-60Hz (AC 85-265V, 47-63Hz); Class I; 1) 12A; 2),3) 16A; Output Ratings: 1) DC 9.6-14.4V (12V), 60A, 720W max.; 2) DC 22.4-33.6V (28V), 36A, 1008W max.; 3) DC 38.4-57.6V (48V), 21A, 1008W max.
Trademark (if any)	TDK-Lambda
Customer's Testing Facility (CTF) Stage used	CTF Stage 2
Model / Type Ref.	1) CPFE1000F-12, 2) CPFE1000F-28, 3) CPFE1000F-48
Additional information (if necessary may also be reported on page 2)	Replaces CB Certificate US-TUVR-9030 due to change of NCB.
A sample of the product was tested and found to be in conformity with	IEC 62368-1:2014 for national differences see test report
As shown in the Test Report Ref. No. which forms part of this Certificate	31081075 300

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland LGA Products GmbH  
Tillystr. 2, 90431 Nürnberg, Germany  
Phone + 49 221 806-1371  
Fax + 49 221 806-3935  
Mail: cert-validity@de.tuv.com  
Web : www.tuv.com

Date: 2021-05-17

Signature:

Dipl.-Ing. M. Glagla