

Certificate



Certificate no.

CU 72205020 01

License Holder:

TDK-Lambda UK Limited
Kingsley Avenue, Ilfracombe
Devon
EX34 8ES
United Kingdom

Manufacturing Plant:

-AK-50418205 001

Test report no.: USA-AK 50418205 004

Client Reference:

Tested to: UL 62368-1:2014
CAN/CSA-C22.2 NO. 62368-1-14

Certified Product: Power Supply

License Fee - Units

Model Designation: 1) DPP960-24-3, 2) DPP960-48-3
(Trademark: TDK-Lambda)

4

Rated Voltage : 3PH 400-500 Vac, 47-63Hz

Rated Current : 2.4A


Output Ratings : 1) DC 24V, 40A, 960W
2) DC 48V, 20A, 960W

Protection Class : I

Rated Ambient Temperature: 50°C

4

Licensed Test mark:



Date of Issue

(day/mo/yr)

03/12/2020