



Ref. Certif. No.

**SI-5170**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE****CERTIFICAT D'ESSAI OC**Product  
Produit

DIN Rail Power Supply

Name and address of the applicant  
Nom et adresse du demandeurTDK-Lambda UK Ltd.  
Kingsley Avenue, Ilfracombe, Devon, EX34 8ES, UKName and address of the manufacturer  
Nom et adresse du fabricantTDK-Lambda UK Ltd.  
Kingsley Avenue, Ilfracombe, Devon, EX34 8ES, UKName and address of the factory  
Nom et adresse de l'usineTDK-Lambda Malaysia Sdn. Bhd.  
Kuantan Lot2&3, Kawasan Perindustrian Bandar Baru Jaya  
Gading, MY-26070 Kuantan, Pahang Darul Makmur, Malaysia*Note: When more than one factory, please report on page 2*  
*Note: Lorsque il y plus d'une usine, veuillez utiliser la 2<sup>ème</sup> page*Ratings and principal characteristics  
Valeurs nominales et caractéristiques principalesInput: 100-240 Vac; 0,39 A max.; 50/60 Hz  
Output: 24-28 Vdc; 0,63-0,54 A; Max. Output power: 15 WTrademark (if any)  
Marque de fabrique (si elle existe)

TDK-Lambda

Type of Manufacturer's Testing Laboratories used  
Type de programme du laboratoire d'essais constructeur

/

Model / Type Ref.  
Ref. De typeDRB15-24-1-xyz  
(Where x,y and z can be any alphanumeric character or blank and is  
non safety relevant information)Additional information (if necessary may also be reported  
on page 2)Les informations complémentaires (si nécessaire, peuvent  
être indiqués sur la 2<sup>ème</sup> pageUnits also complies with EN 60950-1:2006 + A1:2010 + A2:2013  
+ A11:2009 + A12:2011. This CB Test Certificate substitute  
previously issued CB Test Certificate No. SI-3870, dated 2013-07-  
25 due to update of the test report.A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

IEC 60950-1:2005 (Second Edition) + A1:2009 + A2:2013

As shown in the Test Report Ref. No. which forms  
part of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

T223-0102/16

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**SIQ Ljubljana  
Tržaška cesta 2, SI-1000 Ljubljana, Slovenia  
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si  
Product Certification Body is accredited by Slovenian Accreditation, Reg. No.: CP-001

Date: 2016-03-15

Signature: Bojan Pečavar