

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20151015-E476231  
**Report Reference** E476231-20151020  
**Issue Date** 2015-OCTOBER-15

**Issued to:** TDK-LAMBDA UK LTD  
KINGSLEY AVE  
ILFRACOMBE  
EX34 8ES UNITED KINGDOM

**This is to certify that  
representative samples of**

POWER CIRCUIT AND MOTOR-MOUNTED APPARATUS  
FOR USE IN HAZARDOUS LOCATIONS

Open Type Industrial Control Equipment for use in Class I,  
Division 2, Groups A, B, C, D Hazardous Locations.

Switch mode power supply model DRF120-24-1-xyz;  
DRF120-24-1/HL-xyz, where x, y and z can be any  
alphanumeric character or blank and is non safety relevant  
information. HL - designates model provided with coating

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

ISA 12.12.01, Non-Incendive Electrical Equipment for use in  
Class I and II, Division 2, and Class III, Divisions 1 and 2  
Hazardous (Classified) Locations  
CSA C22.2 No. 213-M1987, Non-Incendive Electrical  
Equipment for use in Class I, Division 2 Hazardous  
Locations

**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

