

CERTIFICATE OF COMPLIANCE

Certificate Number 20151015-E476231
Report Reference E476231-20151019
Issue Date 2015-OCTOBER-15

Issued to: TDK-LAMBDA UK LTD
KINGSLEY AVE
ILFRACOMBE
EX34 8ES UNITED KINGDOM

**This is to certify that
representative samples of**

POWER CIRCUIT AND MOTOR-MOUNTED APPARATUS
FOR USE IN HAZARDOUS LOCATIONS

Open Type Industrial Control Equipment for use in Class I,
Division 2, Groups A, B, C, D Hazardous Locations.

Switch mode power supply model DRF480-24-1-xyz;
DRF480-24-1/HL-xyz; DRF480-24-1/HLIVS-xyz, where x, y
and z can be any alphanumeric character or blank and is
non safety relevant information. HL - designates model
provided with coating, HLIVS is model with coating and DC-
rated input

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

ISA 12.12.01, Non-Incendive Electrical Equipment for use in
Class I and II, Division 2, and Class III, Divisions 1 and 2
Hazardous (Classified) Locations

CSA C22.2 No. 213-M1987, Non-Incendive Electrical
Equipment for use in Class I, Division 2 Hazardous
Locations

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

