



Product Service

CERTIFICATE

No. Z2 075029 0030 Rev. 00

Holder of Certificate: **TDK-Lambda Singapore Pte., Ltd.**
1008
Toa Payoh North, #06-01/08 318996
SINGAPORE

Certification Mark:



Product: **Switching power supply unit
(AC-DC Switching Power Supply)**

Model(s): **DRJ120-24-1xy, DRJ120-24-1/xy**
x = E or blank, where E is European terminal type,
blank is block terminal type;
y = CO or CO2 or blank, where
CO is model with thin coating (QMJU2) on one side of PWB,
CO2 is model with thin coating (QMJU2) on both sides of PWB,
blank is model with no thin coating (QMJU2)

Parameters:

Input voltage range:	100~240 Va.c.
Maximum continuous input current:	1.5 Aa.c.
Input a.c. frequency range:	50/60 Hz
Output voltage range:	24-28 Vd.c.
Maximum continuous output current:	5 Ad.c.
Maximum continuous output power:	120 W
Protective class:	I
Operation temperature range:	-25~70 °C

Tested according to: IEC 62477-1:2012
IEC 62477-1:2012/AMD1:2016
EN 62477-1:2012/A12:2021

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290180098503
Valid until: 2028-12-07

Date, 2023-12-08

(Billy Qiu)