ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ СЕРТИФИКАТ ◆ CERTIFICADO ◆ CERTIFICAT
TÜV SÜD

Product Service

CERTIFICATE

No. B 075029 0018 Rev. 00

Holder of Certificate: **TDK-Lambda Singapore Pte., Ltd.**
1008
Toa Payoh North, #06-01/08 318996
SINGAPORE

Production Facility(ies): 026064

Certification Mark:

Product: **Switching power supply unit (AC-DC Switching Power Supply)**

Model(s): **DRJ240-24-1xy, DRJ240-24-1/xy**
[x = E or blank, where E is European terminal type, blank is block terminal type;
y = CO or CO2 or blank, where CO is model with thin coating (QMJU2) on one side of PWB, CO2 is model with thin coating (QMJU2) on both sides of PWB, blank is model with no thin coating (QMJU2).]

Parameters:

Input voltage range:	100~240 Va.c.
Maximum continuous input current:	2.7 Aa.c.
Rated input a.c. frequency:	50/60 Hz
Output voltage range:	24-28 Vd.c.
Maximum continuous output current:	10 Ad.c.
Maximum continuous output power:	240 W
Protective class:	I
Operation temperature range:	-25~70°C

Tested according to: EN 62477-1:2012/A11:2014
IEC 62477-1(ed.1)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 64290180098601
Valid until: 2023-09-26

Date, 2018-09-27 (Billy Qiu)

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

A4 / 07.17